



The State of New Hampshire
Department of Environmental Services



Michael P. Nolin
Commissioner

January 25, 2005

LETTER OF DEFICIENCY #WSEB 05-009
CERTIFIED MAIL #7000 0600 0023 9932 7396

John Kyriazis
Flintlock Apartments LLC
24 Michael Street
Manchester, NH 03104

Subject: Loudon - Public Water System: Flintlock Apartments (EPA #1402010)

Dear Mr. Kyriazis:

The records of the Department of Environmental Services (DES) show that the Flintlock Apartments water system is classified as a public water system (PWS), as defined by RSA 485:1-a. A PWS is defined as any water system serving 15 or more services, or 25 or more people for 60 or more days per year. As such, the water system is required to have a certified operator to operate and maintain the water system to protect public health pursuant to RSA 332-E and New Hampshire Administrative Rule Env-Ws 367.

DES records show that the subject water system failed to obtain a certified operator and as a result an "Important Reminder" letter was issued on November 29, 2004, a copy of which is enclosed. To date, DES has not received any correspondence indicating that the Flintlock Apartments water system has a certified operator (Distribution Grade 1A) as required. If our records are in error and you presently have a certified operator, please notify this office in writing **by February 4, 2005**.

If you do not have a certified operator, DES believes the violation can be corrected by taking the following action:

1. **By February 15, 2005**, obtain a certified Distribution Grade 1A operator to operate and maintain the water system and notify DES in writing of the name and license number of the operator.

Please contact Harrison "Chip" Mackey at (603) 271-2410 or by email at hmackey@des.state.nh.us, if you have any questions regarding the requirements of a certified operator. A listing of firms offering operational services for small water system is available at <http://www.des.state.nh.us/factsheets/ws/ws-7-2.htm>.

Please contact Anne Bailey by phone at (603) 271-0672, or by e-mail at abailey@des.state.nh.us if you have any questions regarding this letter.

Sincerely,

COPY

Sarah Pillsbury, P.G., Administrator
Water Supply Engineering Bureau

h:\wseb\enfmon\enforce\lods\cert.op\2005\1402010.05-009.doc

Enclosures: Certified Operator Letter dated November 29, 2004

cc: Gretchen R. Hamel, DES Legal Unit Administrator
Harrison "Chip" Mackey, DES/WSEB (via e-mail)
Town of Loudon Health Officer
EPA Region 1